

Building Name
 Use Group:
 Inspector:

Location:
 Type of Construction:
 Date:

**TABLE 106 REQUIRED MINIMUM INSPECTIONS
 USE GROUP A, E, I, & R OCCUPANCIES**

VIOLATION CHECKLIST

Section	Emergency Lighting	Location	Comments
1024.0	<input type="checkbox"/> Missing..... <input type="checkbox"/> Inoperable..... <input type="checkbox"/> Exit Discharge.....		
1023.0	Exit Lighting <input type="checkbox"/> Missing..... <input type="checkbox"/> Inoperable..... <input type="checkbox"/> Obstructed.....		
	Doors Fire Doors		
716.5.4	<input type="checkbox"/> Held open by wedges or other means which prevent door from closing <input type="checkbox"/> Missing closer.....		
	Egress Doors		
1014.4.1	<input type="checkbox"/> Has slide bolt/surface..... <input type="checkbox"/> Missing snow guards above door...		
	Exit Access		
1006.2	<input type="checkbox"/> Subject to locking..... <input type="checkbox"/> Pass through (Toilet room, dwelling units, etc).....		
	Accessible Doors		
AAB 26.9	<input type="checkbox"/> Closing time less than minimum 6 seconds from open position of 90 degrees.....		
1028.0	Egresses - Stairs/Handrails/Guards <input type="checkbox"/> Keep egresses free and clear at all times..... <input type="checkbox"/> Repair rubber treads or carpeting...		
1022.0	<input type="checkbox"/> Repair all damaged wood.....		
AAB 22.4.1	<input type="checkbox"/> Missing graspable handrails.....		
1028.1	<input type="checkbox"/> Threshold to accessible area exceeds 1/2"..... <input type="checkbox"/> Aisle width - minimum size.....		
920.0	Fire Extinguishers <input type="checkbox"/> Missing..... <input type="checkbox"/> Approval - Tag out of date.....		

Woodstove

Combustible within 36" or not in accordance with manufactures specs..

Missing 3 screws/section stove pipe.....

_____	_____
_____	_____
_____	_____
_____	_____

Ducts

Replace duct tape with approved foil tape.....

_____	_____
_____	_____

Vapor Barrier

Exposed poly or proper vapor barrier, cover with approved materials.....

_____	_____
_____	_____
_____	_____